

Southern California Edison
2023-WMPs – 2023-WMPs

DATA REQUEST SET M G R A - S C E - 0 0 4

To: MGRA

Prepared by: Jesse Rorabaugh

Job Title: Senior Engineer

Received Date: 5/8/2023

Response Date: 5/11/2023

Question 02:

What has been the in-service up-time of installed GFNs in 2023?

Response to Question 02:

As of May 8, 2023, the Ground Fault Neutralizer at Neenach substation has been in service for 1,761 hours (73.3 days) since the start of the year. The Ground Fault Neutralizers at Acton and Phelan substations are on the foundations with ongoing construction but have not yet been placed into service.