

Location Properties

Technician:

Address:

City:

County:

Cross Street 1:

Remedy:

Comments:

Map Number:

Pole Tags:

State:

Zip Code:


Cross Street 2:

Summary Notes:

Location Analysis Summary

Layer	Pole Length/Class	Minimum Safety Factor						Pole Strength Remaining	Loading Adjusted by Strength?	Clearance Violations Present?
		Pole	Guy	Anchor	Cross Arm	Insulator	Sidewalk Brace			
As Designed	55'/H2	3.32 from stress at 3' 3"	No Data	No Data	No Data	No Data	No Data	100%	Y	N

Measured: As Designed



Analysis Results

Loading

Component	New, 12 lb, Grade A (Governing Case)			Client File Maximum Rating
	Safety Factor	Load (Applied / Allowable)	Wind Direction	
Pole	3.32 from stress at 3' 3"	2291 / 7600 lb/in ²	210 °	7600 lb/in ²

Wire End Points and Wires

WEP#1												
Type	Environment	Distance	Direction	GPS Point	Inclination	Measured Between	Measured to Ground					
Next Pole	None	159'	275 °	Undefined.	0 °	N/A	N/A					
ID	Size	Owner	Group	Tension Group	Height	Midspan	TAF	Initial Tension	Tension Method	New, 12 lb, Grade A		
										Tension	Sag	
Wire#12	1/0 ACSR Tree Wire XLPE	SCE	Primary	Light Reduced Unguyed	46' 9"	0' 0"	1	88 lbf*	Dynamic	160.87 lbf**	13' 0"***	
Wire#3	1/0 ACSR Tree Wire XLPE	SCE	Primary	Light Reduced Unguyed	46' 9"	0' 0"	1	88 lbf*	Dynamic	161.47 lbf**	13' 0"***	
Wire#6	1/0 ACSR Tree Wire XLPE	SCE	Primary	Light Reduced Unguyed	46' 9"	0' 0"	1	88 lbf*	Dynamic	161.04 lbf**	13' 0"***	
Wire#11	.5" CATV 5/16" Messenger	Unknown	Communication	Light Full	24' 2"	0' 0"	1	1201 lbf*	Dynamic	799.05 lbf**	2' 3"***	
Wire#9	1" CATV 1/4" Messenger	Unknown	Communication	Light Full	24' 0"	0' 0"	1	840 lbf*	Dynamic	935.98 lbf**	3' 2"***	

WEP#2												
Type	Environment	Distance	Direction	GPS Point	Inclination	Measured Between	Measured to Ground					
Previous Pole	None	134'	129 °	Undefined.	0 °	N/A	N/A					
ID	Size	Owner	Group	Tension Group	Height	Midspan	TAF	Initial Tension	Tension Method	New, 12 lb, Grade A		
										Tension	Sag	
Wire#13	1/0 ACSR Tree Wire XLPE	SCE	Primary	Light Reduced Unguyed	46' 9"	0' 0"	1	73 lbf*	Dynamic	171.95 lbf**	9' 11"***	
Wire#4	1/0 ACSR Tree Wire XLPE	SCE	Primary	Light Reduced Unguyed	46' 9"	0' 0"	1	73 lbf*	Dynamic	171.06 lbf**	10' 0"***	
Wire#5	1/0 ACSR Tree Wire XLPE	SCE	Primary	Light Reduced Unguyed	46' 9"	0' 0"	1	73 lbf*	Dynamic	172.38 lbf**	9' 11"***	
Wire#7	4 Al. Triplex	SCE	Secondary	Light Full	29' 6"	0' 0"	1	282 lbf*	Dynamic	385.12 lbf**	3' 9"***	
Wire#10	.5" CATV 5/16" Messenger	Unknown	Communication	Light Full	24' 2"	0' 0"	1	1201 lbf*	Dynamic	618.29 lbf**	2' 3"***	
Wire#8	1" CATV 1/4" Messenger	Unknown	Communication	Light Full	24' 0"	0' 0"	1	840 lbf*	Dynamic	822.99 lbf**	2' 11"***	

*Tension value used in an analysis may vary dependent on 'Average Length on Main Span' setting in the Load Case.

** Tension value is inclusive of environmental and load factors associated with the Load Case.

*** Sag value is inclusive of environmental and load factors associated with the Load Case.

Equipment

ID	Size	Owner	Type	Height	Bottom Height	Direction
Equip#1	Fuse Arm with 3 Cutouts	SCE	Cutout Arrestor	46' 6"	46' 6"	202 °
Equip#2	2 PVC	SCE	Riser	28' 6"	0' 0"	165 °

Cross Arms

ID	Size	Height	Association	Direction	Offset	Insulators
CrossArm#2	5 Foot Double Cross Arm	24' 0"	Other	199 °	2' 6"	Insulator#8
CrossArm#1	12 Foot Double Cross Arm	46' 6"	Bisector	202 °	6' 0"	Insulator#1, Insulator#2, Insulator#3, Insulator#4, Insulator#5, Insulator#6, Insulator#9, Insulator#10, Insulator#11

Insulators

ID	Size	Direction	Offset	Wires
Insulator#7	3" Spool Bolt	133 °	29' 6"	Wire#7
Insulator#8	3" Clevis Insulator	129 °	0' 4"	Wire#10, Wire#11
Insulator#1	16 kV Deadend	275 °	0' 4"	Wire#12
Insulator#2	16 kV Deadend	129 °	0' 4"	Wire#5
Insulator#3	16 kV Deadend	275 °	11' 8"	Wire#3
Insulator#4	16 kV Deadend	129 °	11' 8"	Wire#4
Insulator#5	16 kV Deadend	275 °	4' 1"	Wire#6
Insulator#6	16 kV Deadend	129 °	4' 1"	Wire#13
Insulator#9	16 kV Pin (Cross Arm)	0 °	0' 4"	
Insulator#10	16 kV Pin (Cross Arm)	0 °	4' 1"	
Insulator#11	16 kV Pin (Cross Arm)	0 °	11' 8"	

Location 4548126E Location Forms

SAP

- Field Inspection Date: 11/30/2022
- High Fire: Extreme
- Special Project: No
- Associated Poles:
- Visible Damage: No
- Pole Type: ED
- District: 59 - Valencia
- Region: -
- Above 3000 Ft Elevation: No
- As Designed Work Type: Replace
- Access Notes:

Pole Info Form

- Pole Equipment #:
- Previous Inspection Date:
- Year Installed:
- As Is POA Height:
- As Is POA Diameter:
- As Designed POA Height:
- As Designed POA Diameter:
- Thomas Guide/Quadrant:
- Circuit :
- Substation:
- FIM:
- Location:
- City:
- Brand Height:
- Date Pole Load Performed:
- Comments:
- GPS Location: N/A

QC Comments

- QC Comments: