

Southern California Edison
2023-WMPs – 2023-WMPs

DATA REQUEST SET O E I S - P - W M P _ 2 0 2 3 - S C E - 0 0 5

To: Energy Safety
Prepared by: Kevin Arlic
Job Title: Senior Manager
Received Date: 5/25/2023

Response Date: 5/31/2023

Question 02. c:

Regarding SCE's Asset Inspection Program

c. If SCE tailors its inspections specifically to inspect wildfire risk specific items, identify which items within the checklist this applies to, particularly if such differs from standard GO 95 inspections.

Response to Question 02. c:

SCE's annual grid patrol and detailed inspections are used to identify GO 95 safety and reliability issues in accordance with GO 165 timing. Although a checklist is neither required nor completed, further details regarding methods and procedures for the patrol can be referenced within the file: "*Distribution Inspection and Maintenance Program (DIMP)*." SCE detailed inspections go beyond this in HFTD to identify conditions that may not be a specific focus in GO 95, but still pose safety and reliability risk, as well wildfire risk.

SCE's inspection form has been updated as SCE's understanding of wildfire risk has evolved, and to formalize questions that inspectors are required to address in their inspections. In some cases, this involved the identification of specific types of issues in the checklist for which inspectors are specifically required to evaluate. To this end, SCE added questions to its inspection checklist performed within HFTD to help identify issues that may indicate wildfire risk. Additionally, SCE has added questions to the inspection checklist to capture additional asset-related data that can be useful to incorporate into SCE's wildfire risk assessments. This data helps to provide information for evaluating wildfire risk and to maintain current and relevant data for SCE assets within its HFTD.

Please refer to the file "*Distribution Inspection Survey Questions_2022*" which indicates several of these questions that SCE has added to its HFTD checklist since its inception in 2020. SCE indicates the question ID, which can be cross-referenced to the full question text and responses in the file "*Distribution Ground InspectApp Survey Approved 2022-05-20*."