

Southern California Edison
2026-WMPs – 2026-WMPs

DATA REQUEST SET M G R A - S C E - 0 0 6

To: MGRA

Prepared by: Jonathan Brownstein

Job Title: Engineering Manager

Received Date: 6/10/2025

Response Date: 6/13/2025

Question MGRA-6-2:

MGRA 5-2 requested that root cause information be provided for the 2024 reportable ignitions. The provided response does not contain cause information.

Provide non-confidential root cause summaries for these ignitions.

Response to Question MGRA-6-2:

SCE objects to this Question as vague and ambiguous. Subject to these objections, SCE responds as follows:

For the three line items referenced in SCE's previous response to data request MGRA-5-2, SCE provided suspected initiating events in columns P, Q, and R and contributing factors in column T of the spreadsheet attachment. Below is additional information for each of the “suspected initiating events” in column P of the spreadsheet for each of those three line items:

- Line [1] – “Contact From Object” refers to a vehicle hitting our pole.
- Line [2] – “Equipment/Facility Failure” refers to a splice failure.
- Line [3] – “Contact From Object” refers to a vegetation tree fall-in.