

Southern California Edison
2026-WMPs – 2026-WMPs

DATA REQUEST SET O E I S - P - W M P _ 2 0 2 5 - S C E - 0 0 2

To: Energy Safety
Prepared by: Napa Tayavibul
Job Title: Senior Advisor
Received Date: 5/23/2025

Response Date: 5/29/2025

Question 02.a-b:

Regarding Work Order Priority Levels:

On page 366 of its 2026-2028 WMP, SCE identifies two categories that designate a tree as requiring work within a Priority 1 timeline: 24 hours and 72 hours. Furthermore, SCE identifies four categories that designate a tree as requiring work within a Priority 2 timeline. The four categories are as follows (abbreviations and timelines to complete work are in parentheses): within Regulatory Clearance Distance (RCD; less than 30 days), between RCD and Trigger Clearance Distance (RCD; less than 90 days), hazard management and dead and dying trees (less than 180 days), and strain or abrasion to secondary distribution lines. SCE does not include a timeline to remove strain or abrasion due to trees contacting secondary distribution lines.

- a. Specify what timeline SCE has set to mitigate tree contact causing strain or abrasion to secondary distribution lines.
- b. Complete the table, below, to disaggregate the Priority 1 and Priority 2 condition timeline categories.

*Number of Past Due Vegetation Management Work Orders
by Age and Priority Level Timeline Category*

Priority Level	0-30 Days	31-90 Days	91-180 Days	181+ Days	Total
Priority 1 (24 hours)					
Priority 1 (72 hours)					
Priority 2 - Less than RCD (<30 days)					
Priority 2 - Between RCD and TCD (<90 days)					
Priority 2 - Hazard Tree Management and Dead and Dying Tree (<180 days)					
Strain or Abrasion on Secondary Lines					

Response to Question 02.a-b:

Please see SCE's response to OEIS' questions below.

- a.) When vegetation is found to be causing strain and abrasion on secondaries, remediation is performed within the guidelines of GO95 Rule 18A as a level 2 and typically mitigated within 90 days.

- b.) SCE presents the information below in the requested table format, disaggregating the P1 and P2 categories as of 3/7/25. This information was also provided in SCE's 2026-2028 WMP, Table 9-8; however, the P2 category in the WMP also included 2,599 past due vegetation management work orders for P2s with \geq GRCD (180 days). As a result, the total number of past due vegetation management work orders identified in this response will vary from the totals shown in SCE's 2026-2028 WMP, Table 9-8.

Priority Level	0-30 Days	31-90 Days	91-180 Days	181+ Days	Total
Priority 1 (24 hours)	0	0	0	0	0
Priority 1 (72 hours)	0	0	0	0	0
Priority 2 - Less than RCD (<30 days)	1,727	55	22	2	1,806
Priority 2 - Between RCD and TCD (<90 days)	11,751	117	108	67	12,045
Priority 2 - Hazard Tree Management and Dead and Dying Tree (<180 days)	30	25	141	89	285
Strain or Abrasion on Secondary Lines ¹	N/A	N/A	N/A	N/A	N/A

Lastly, SCE clarifies that timelines associated with the remediations are internal guidelines and are not formal WMP targets. As noted in the UVM documents, these timelines may be subject to various constraints.

¹ Strain or Abrasion on Secondary Lines is not a formal category SCE tracks as part of its vegetation management inspections.