

Southern California Edison
2026-WMPs – 2026-WMPs

DATA REQUEST SET O E I S - P - W M P _ 2 0 2 5 - S C E - 0 0 7

To: OEIS
Prepared by: Eghosa Obasohan
Job Title: Senior Advisor
Received Date: 6/10/2025

Response Date: 6/13/2025

Question 02.a-e:

VM-8 Targets:

In Table 4-1 on page 27 of the 2026-2028 Base WMP, SCE lists 1,988 circuit miles of overhead transmission lines in HFTD Tier 2 and 2,429 circuit miles in HFTD Tier 3, for a total of 4,417 circuit miles within the HFTD. In Table 9-2 on page 331 of the 2026-2028 Base WMP, for Inspections for Vegetation Clearance from Transmission Lines (VM-8) SCE lists a “Cumulative Quarterly Target for 2026, Q4”, of “3,800 circuit miles within transmission system in HFRA”, a “% HFTD Covered in 2026” of “100%”, and a “% Risk Reduction for 2026” of “0.37%”.

- a. Provide the number of transmission circuit miles within SCE’s HFRA.
- b. Provide the percentage of transmission circuit miles within the HFTD that are also within SCE’s HFRA.
- c. Explain the difference in the HFTD circuit miles listed in Table 4-1 and the VM-08 target.
- d. Is the “% of HFTD Covered in 2026” in Table 9-2 for VM-8 calculated using the 3,800 circuit mile target as the total number of circuit miles inspected?
 - i. If no, provide the values used to calculate “% HFTD Covered in 2026” and explain how they were chosen.
 - ii. If no, provide the “% of HFTD Covered in 2026” using the 3,800 circuit mile target as the total amount of work done.
- e. Is the “% Risk Reduction for 2026” in Table 9-2 for VM-8 calculated using the 3,800 circuit mile target as the total number of circuit miles inspected?
 - i. If no, provide the values used to calculate “% Risk Reduction for 2026” and explain how they were chosen.
 - ii. If no, provide the “% Risk Reduction for 2026” using the 3,800 circuit mile target as the total number of circuit miles inspected.

Response to Question 02.a-e:

- a. SCE clarifies that the % HFTD covered in 2026 for VM-8 is 86% rather than 100% documented in Table 9-2. SCE identified this typographical error and will submit a correction as part of non-substantive errata due by 6/30/25. SCE also identified a similar typographic error for the % HFTD covered in 2026 for VM-7 and will correct this as part of the non-substantive errata.
- b. 100% of transmission circuit miles in HFTD are within SCE’s HFRA. SCE uses a 200-foot buffer extended from the HFTD to account for possible internal mapping discrepancies of assets as an additional margin for scoping enhanced wildfire mitigation activities.
- c. Please refer to the response to 2a above.

- d. Yes, % HFTD covered in 2026 is calculated using the 3,800 transmission circuit miles target out of the total of 4,417 transmission circuit miles, which equals 86%. Please refer to the response to 2a above for additional details.
- e. Yes.