

# INTERRUPTION REPORT

**Interruption#:** 12722-2025

**CLOSE**

**Actual Date:** 01/15/2025 14:01

**All Load UP:** 01/16/2025 01:32

**Part Load UP:** 01/15/2025 15:04

**Distribution Status:** Restored

**Related Request?**

**Primary Switching Center:** Valley

**RAR:** NA

## INTERRUPTION DETAILS

### Outage Line/Equipment

Region	SW Center	Type	Station	Line/Equipment Name	Out Date/Time	Duration
District	A Bank	kV			Restore Date/Time	
	Valley	BREAKER	Tenaja	Corinth 12kV CB	01/15/2025 14:01	0d 11h 31m 0s.
	Valley	12			01/16/2025 01:32	

### Device Operation Summary

Station - Device	#OPs	Targets	CBC	Out Date	Duration	Fault Type	Distance
				Restore Date		Fault Magnitude	
Tenaja - Corinth 12kV CB	3	A PH FAULT,B PH FAULT,G FAULT		01/15/2025 14:01 01/16/2025 01:32	0d 11h 31m 0s		0

### Sequence of Operations

Station	Device	Operation	How	Date/Time
---------	--------	-----------	-----	-----------

### Weather:

### Weather Condition:

**Cause Category:** UG EQUIPMENT

**Sustained Cause Category:**

**Cause:** PMH-PME SWITCH , OTH-SEE  
NOTES

**Sustained Cause:**

### Event Description:

Corinth 12kV line relayed with recloser solid and fast curve automatic for red flag. Circuit is locked out.  
Replace blown PME 5060

### Event Activity

Date/Time	Comments
01/15/2025 14:01	Corinth 12kV line relayed with recloser solid and fast curve automatic for red flag. Circuit is locked out.
01/15/2025 14:01	Made the Corinth 12kV fast curve solid.
01/15/2025 14:02	RCS 1100 opened on LVA, dead section of the Corinth 12kV line.
01/15/2025 14:31	TM, [REDACTED] reports no indication at FI 00837 and positive indication at FI07815, Corinth 12kV line.
01/15/2025 14:39	TM, [REDACTED], reports no indication at FI 01000, Corinth 12kV line.
01/15/2025 14:55	TM, [REDACTED] reports no indication at FI 07816, Corinth 12kV line.
01/15/2025 14:55	Operator, [REDACTED], reports CB open, 3 operations, A/B/C phase targets and equipment checks OK at Tenaja Substation.
01/15/2025 15:03	TM, [REDACTED], reports patrolled 322 up to open RCS 1100. Reported to have found small vegetation fire at the base of 315548S but no damage to our primary wire or equipment. Does not appear to be related to the relay operation. Request a test to open RCS 1100 while monitoring at the base of 315548S.
01/15/2025 15:04	Closed the Corinth 12kV CB, energizing and testing a section of the Corinth 12kV line to open RCS 110 and various ends. Part Load Up.
01/15/2025 15:45	TM, [REDACTED], reports blown PME 5060, Corinth 12kV line.
01/15/2025 15:49	Opened Pos. 1 of GS 5760, dead section of the Corinth 12kV line.
01/15/2025 15:59	Opened Pos. 1 of GS 5798, dead section of the Corinth 12kV line.

# INTERRUPTION REPORT

Interruption#: 12722-2025

CLOSE

Actual Date: 01/15/2025 14:01

All Load UP: 01/16/2025 01:32

Part Load UP: 01/15/2025 15:04

**Event Activity**

Date/Time	Comments
01/15/2025 16:00	Closed RCS 1100, energizing and testing a section of the Corinth 12kV line to open Pos. 1 of GS 5798 and various ends. Tested good for More Load Up.
01/15/2025 16:00	Closed 2 of GS 1590, energizing and testing a section of the Corinth 12kV line via the Leon 12kV line to open Pos. 1 of GS 5760 and various ends. Tested good for More Load Up.
01/15/2025 16:01	Made the Corinth 12kV fast curve automatic.
01/15/2025 21:29	Made the Corinth 12kv recloser solid. Made the Leon 12kv recloser solid.
01/15/2025 21:30	██████ has No Test Orders on the Corinth 12kv line. ██████ has No Test Orders on the Leon 12kv line.
01/16/2025 01:32	Closed Pos.1 of GS 5798 energizing and testing a section of the Corinth 12kv line to Open PS 7095, and Open Pos. 1 of GS 5760 for ALU.
01/16/2025 01:41	Closed Pos.1 of GS 5760 making a parallel between the Corinth and Leon 12kv lines.
01/16/2025 01:51	Opened Pos. 2 of GS 1590 breaking parallel between the Corinth and Leon 12kv lines.
01/16/2025 02:04	██████ cancels No Test Orders on the Leon 12kv line. ██████ cancels No Test Orders on the Corinth 12kv line.
01/16/2025 02:14	Made the Corinth 12kv recloser automatic.
01/16/2025 02:14	Made the Leon 12kv recloser automatic.

**Reporting Flags**~~NTO~~ - NTO Cancelled~~NTO~~ - NTO Cancelled**Followup Required:****Fault Location(s)**

Station	Structure	Description
Tenaja		