

Southern California Edison Company		
Monthly Peaks and Energy @ ISO (MWh)		
Month	Peak	Energy
Jan	11,430	6,862,713
Feb	10,885	6,204,701
Mar	10,580	6,641,335
Apr	11,916	6,546,329
May	12,969	7,156,390
Jun	16,212	7,941,011
Jul	19,101	9,092,199
Aug	19,722	9,306,521
Sep	19,737	8,429,678
Oct	16,191	7,314,376
Nov	11,830	6,542,246
Dec	11,453	6,931,857
Total	172,025	88,969,356

Southern California Edison Company	
2024 Monthly Eastwood Pump Amounts	
Month	Energy (MW)
Jan	
Feb	
Mar	
Apr	
May	
Jun	
Jul	14,709
Aug	28,671
Sep	13,057
Oct	
Nov	4,175
Dec	20,144
Total:	80,756

2024 True-Up Calculation		
2024 Forecast (MWh)	65,258	Reference: TO2025 Schedule 32, Line 2
True-Up Calculation (MWh)	15,498	= Total 2024 Actuals less 2024 Forecast

Note that the full return to service for Eastwood was delayed until mid-July 2024, which is why there was no pump activity in June 2024. The unit was in outage in October and for part of November 2024. For the months where the pump usage was higher than forecasted, it was due to a combination of favorable prices and meeting reliability obligations.

Southern California Edison Company	
2025 Monthly Eastwood Pump Forecast Amounts	
Month	Energy (MW)
Jan	9,960
Feb	24,231
Mar	3,422
Apr	23,118
May	17,800
Jun	14,012
Jul	18,495
Aug	18,789
Sep	19,040
Oct	23,871
Nov	
Dec	21,208
Total:	193,946